

Fire Protection Survey Services™

2403 Fairgrounds Road
Washago, Ontario, Canada, L0K 2B0

Telephone: (249) 359-7231

E-mail: fpss@xplornet.ca Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: Township of North Stormont

ACCREDITED FIRE STATIONS

Avonmore F.S.

Crysler F.S.

Finch F.S.

Moose Creek F.S.

Date Test Passed: _____ **October 14, 2017**

Flow Achieved: 660 I.G.P.M. 3000 LITERS/MIN.

Two (2) Hour Test Time

Signed: Peter J. Rose

Peter J. Rose, C.E.T., F.P.T.
Senior Fire Protection Specialist
Senior Loss Control Specialist

