



November 22, 2021,

Posted in PDF (1 pages)

**ADDENDUM NO. 4
REQUEST FOR PROPOSAL FRQ-FD02-2021
CLOSING: 2:00PM (LOCAL TIME), November 26, 2021**

For: Chrysler Firehall

- 1) On the electrical single line diagram on drawing E2. The service is calling for a 225A cold disconnect before the meter. Is this what you are looking for or is this just a typo and it will be a standard service with the meter and then the 225amp panel with disconnect

Electrical Service shall be installed in accordance with Electrical Single Line Diagram on Dwg E2.

- 2) There is a requirement to insulate RH-1: Range Hood EA 10"*4". The insulation specification only mentions fiberglass insulation (rigid/rectangular, flex/round) on all HVAC requirements. Generally, our experience is that range hood duct is often insulated with a fire rated produced (ie 1 hour, or 2 hour 3M Firemaster). Can you please confirm this insulation selection.

This is not a commercial kitchen exhaust and is a residential type range hood for the stove unit. No fire rating is required.

END ADDENDUM NO. 4